

NOTICE

**OFFICE OF THE CHIEF DISTRICT MEDICAL & PUBLIC HEALTH OFFICER: JAJPUR**

No. 1582 / DT. 25.02.21

**TENDER CALL NOTICE**

Sealed Tenders are invited for Supply of Inverter & Stabilizer to the cold chain point of Jajpur district. The Intending Tenderers may obtain Tender paper containing terms & conditions details available in the district website [www.jajpurnic.in](http://www.jajpurnic.in). The Sealed Tender papers are to be submitted through Regd.post/Speed Post up to 2.00 P.M on dated 12.03.2021 to the Chief District Medical & Public Health Officer, Jajpur At/Po/Dist. Jajpur Pin-755001.

Sd/-Dr.S.S.Bal  
CDM&PHO, JAJPUR

Chief District Medical & Public Health Officer  
Jajpur

**OFFICE OF THE C.D.M & P.H.O, JAJPUR**

**TENDER DOCUMENT FOR PROVISION TO INVERTER & STABILIZER FOR STRENGTHENING  
IMMUNIZATION ACTIVITIES IN JAJPUR DISTRICT.**

**TERMS AND CONDITIONS**

- Sealed Tender are invited from the interested firms/agencies/organization/proprietor for supply of Inverter & Stabilizer in Jajpur District as per specification given details in "Annexure-B"
- Last date for submission of Tender-Dt.12.03.2021 Time 02.00P.M
- Tender open date Dt.17.03.2021 Time 11.00A.M
- Address: O/O The CDM & PHO, Jajpur At/Po-Jajpur, Dist-Jajpur, Pin No-755001

**Document to be submitted**

- A) Copy of valid GST Registration Certificate.
- B) Copy of PAN Card.
- C) Affidavit (Notary/Executive magistrate) of Non-black listed firms for execution of Govt. similar works.
- D) Registration copy of (Firm/agency/Organization/Proprietor)
- E) Annual Turnover document.
- F) Under taking for supply of Inverter & Stabilizer as per the specification only.

**Signing of Documents**

- All Papers/documents submitted with the Tender must be signed by the Bidder or his/her authorized representatives.

**Submission of Bid Documents**

- The Bidder must submit the technical Bid "Annexure-A" & Financial Bid "Annexure-B" under two bid system separately in the sealed envelope & both the Technical & Financial Bid Envelops must be kept in another envelope (Outer).The outer Envelop must be superscribed on the top of the envelop "Proposal for supply of "Inverter & Stabilizer" and to be addressed to the Chief District Medical & Public Health Officer, At/Po/Dist-jajpur,PIN-755001.

**Validity**


- The rate must be quoted as per specification, term & condition and will be valid for one year from date of finalization of Tender.(It will be extended for another one year subject to satisfactory performance as per recommendation of the purchase committee.)
- The rate quoted by the firms/agencies/organizations/proprietor should be including of all Taxes/transportation with installation charges & etc in PHC (N)s/CHCs/PPC/DVS level Cold Chain Point in Jajpur District.(Statement-1 enclosed herewith)
- The supplied equipment not working during Warranty/Guaranty period, the bidder will take necessary step at their level to repair/replace & etc of the equipment with the support of the undersigned.
- The undersigned reserves all the rights to cancel or reject the any or all Tender without assigning any reason thereof. The decision of the committee will be treated as final.

Chief District Medical  
& Public Health Officer,  
Jajpur

➤ **EARNEST MONEY:-**

- Bidders are to furnish E.M.D Rs.10000/-(Rupees Ten thousand) only in the shape of B.D as indicated in para-3.2.
- EMD shall be furnished in form of bank Draft only drawn in favour of the ADPHO (FW) Jajpur and attached to each tender paper. The Bank Draft to be drawn in concerned nearest State Bank of India Branch.
- To facilitate immediate refund of E.M.D, the tender should submit separate Bank Draft against which they have tendered with a stapled slip to each Bank Draft. If it is not done, so the conducting Authority (CDM&PHO) may not be responsible for early refund of E.M.D, in case successful Tenders. The E.M.D of L-1, L-2 & L-3 Tenderers shall not be refunded until the successful tenders and Tender finally decided.
- E.M.D of un- successful Tenderer will be refunded after finalization of tender and within 30 days. No interest will be claimed by the Tenderer.

Chief District Medical  
& Public Health Officer,  
Jajpur



Annexure-'A'

TECHNICAL BID

1. Name of the Firm/agency/Organization/Proprietor-  
(Proof of Registration to be submitted)
2. Address of the Firm/Agency/Organization/Proprietor-
3. Name of the contact person (Bidder)-
4. E-Mail of the Firm/Agency/Organization/Proprietor-
5. Contact Number-
6. PAN Card No (Firm/Agency/Organization/Proprietor (Copy to be attached)-
7. GST Registration Number (Copy to be attached)-
8. Registration copy of Firm/Agency/Organization/Proprietor-
9. Annual Turnover in. Rupees \_\_\_\_\_  
(Firm/Agency/Organization/Proprietor)Copy to be attached-
10. Affidavit (Notary/Executive magistrate) of Non-blacklisted firms for execution of Govt.Similar works-
11. Undertaking for supply of the materials as per specification only-

Signature of Bidder

  
Chief District Medical  
& Public Health Officer.  
Jaipur

**FINANCIAL BID WITH SPECIFICATION OF INVERTER & STABILIZER FOR STRENGTHENING  
IMMUNIZATION ACTIVITIES IN JAJPUR DISTRICT**

- **Inverter-Capacity-2000 Watt/24V.DC**
- Phase-Single
- Input Voltage-100V-280V
- Output Voltage-220V
- Battery Capacity-2 Nos.(150 Ah,12V.DC each)
- Frequency-50Hz
- Pure Copper transformer.
- Brand:-
  
- **Battery-2 nos (150 Ah, 12V.DC each)**
- Battery type- Flat plate, Tubular, Lead Acid
- Other features- Battery deep charge protection.
- Recharge time-10-12 hrs.
- Brand:-
  
- **Capacity-1KVA**
- Input Voltage-90 V-280V
- Inbuilt MCB-10 Amps
- Wall Hanging
- Time Delay-6 to minutes
- Inbuilt thermal overload protector.
- Ultra durable high grade plastic material suitable for Tall Tubular battery.
- Dimension-60X50.5X32 cm.

N.B The rate quoted by the firms/agencies/organizations/proprietor should be including of all Taxes/transportation with installation charges & etc in PHC (N)s/CHCs/PPC/DVS level Cold Chain Point in Jajpur District.

Signature of Bidder

  
Chief District Medical  
& Public Health Officer,  
Jajpur

"Annexure-C"

**DECLARATION**

I Mr./Mrs. \_\_\_\_\_ on behalf of

\_\_\_\_\_  
(Firm/agency/Organization/Proprietor Name) declared that I/we are not blacklisted by any central Govt./state Govt./Public sector undertaking in India. I have given consent that, the supply of above materials will be completed in the stipulated time as per given specification. I conform that, the information that I have provided above is true & correct in the best of my knowledge.

Signature of Bidder

Chief District Medical  
& Public Health Officer  
JALNAR



**Requirement of Inverter & Automatic Voltage Stabilizer, Sub meter for dedicated Power supply to the following ILR Points.**

**Distance from District Head Quarter Hospital, Jaipur to ILR Point**

Sl.No	Name of the ILR Point	Approximately Distance(in Kilometer)	Remarks
1	Jari PHC(N)	30	INVERTER
2	Binjharpur CHC	16	INVERTER
3	Pritipur PHC(N)	50	INVERTER
4	Mangalpur CHC	50	INVERTER
5	Dasarathapur CHC	30	INVERTER
6	Ahiyas PHC(N)	50	INVERTER
7	Markandapur CHC	24	INVERTER
8	Adampur PHC(N)	30	INVERTER
9	Sujanpur PHC(N)	30	INVERTER
10	Bari CHC	60	INVERTER
11	Ratnagiri PHC(N)	90	INVERTER
12	Balia PHCN)	60	INVERTER
13	Haripur PHC(N)	26	INVERTER
14	Singhapur PHC(N)	50	INVERTER
15	Brahmabarada PHC(N)	40	INVERTER
16	Panikoili PHC(N)	40	INVERTER
17	Pachikote PHC(N)	80	INVERTER
18	BT Road PHC(N)	30	INVERTER
19	Sankhachila PHC(N)	60	INVERTER
20	Gabardhanpur PHC(N)	130	INVERTER
21	Jakhapura PHC(N)	40	INVERTER
22	Sukinda CHC	120	INVERTER
23	Duburi PHC(N)	100	INVERTER
24	Hatibari PHC(N)	140	INVERTER
25	Dharmasala CHC	70	INVERTER
26	Jenapur PHC(N)	90	INVERTER
27	Kabatabandha PHC(N)	100	INVERTER
28	Gadamadhupur PHC(N)	84	INVERTER
29	Chatia PHC(N)	120	INVERTER
30	Gopalpur PHC(N)	84	INVERTER
31	Darpani PHC(N)	100	INVERTER

Chief District Medical  
& Public Health Officer,  
Jaipur

*[Handwritten Signature]*  
12/11

Sl.No	Name of the ILR Point	Approximately Distance(in Kilometer)	Remarks
1	Mangalpur CHC	50	Stabilizer(Normal)
2	Dasarathapur CHC	30	Stabilizer(Normal)
3	Ahiyas PHC(N)	50	Stabiliser(Normal)
4	Chandipur S/C	58	Stabiliser(Normal)
5	Kamagarh S/C	10	Stabiliser(Normal)
6	Binjharpur CHC	32	Stabiliser(Normal)
7	Kantipur PHC(N)	52	Stabiliser(Normal)
8	Bari CHC	60	Stabiliser(Low)
9	Balia PHC(N)	60	Stabiliser(Normal)
10	Krushnanagar PHC(N)	80	Stabiliser(Normal)
11	Singhapur PHC(N)	50	Stabiliser(Normal)
12	Jenapur PHC(N)	90	Stabiliser(Normal)
13	Kabatabandha PHC(N)	100	Stabiliser(Normal)
14	Haridaspur PHC(N)	78	Stabiliser(Low)
15	Kotpur PHC(N)	60	Stabiliser(Low)
16	Barchana CHC	100	Stabiliser(Normal)
17	Darpani PHC(N)	100	Stabiliser(Normal)
18	Chatia PHC(N)	120	Stabiliser(Normal)
19	Bausamuli PHC(N)	130	Stabiliser(Low)
20	Kuhika PHC(N)	140	Stabiliser(Normal)
21	Tisco PHC(N)	155	Stabiliser(Normal)
22	Duburi PHC(N)	100	Stabiliser(Normal)
23	Jakhapura PHC(N)	80	Stabiliser(Normal)
24	Masudpur PHC(N)	42	Stabiliser(Normal)
25	Gopalpur PHC(N)	84	Stabiliser(Normal)
26	Laxminagar PHC(N)	70	Stabiliser(Normal)

Chief District Medical  
& Public Health Officer,  
Jaipur

Sl.No	ITEM Name	SPECIFICATIONS	REMARKS
1	UPS(for Inverter)	Capacity-2000 Watt/24V.DC Phase-Single Input Voltage-100V-280V Output Voltage-220V Battery Capacity-2 Nos.(150 Ah,12V.DC each) Frequency-50Hz Pure Copper transformer.	
2	Battery(for Inverter)	Battery-2 no (150 Ah,12V.DC each) Battery type-Flat plate,Tubular,Lead Acid Other features-Battery deep charge protection. Recharge time-10-12 hrs.	
3	Normal Voltage Stabilizer	Capacity-1KVA Input Voltage-130 V-280V Inbuilt MCB-10 Amps Wall Hanging Time Delay-6 to minutes Inbuilt thermal overload protector.	
4	Low Voltage Stabilizer	Capacity-1KVA Input Voltage-90 V-280V Inbuilt MCB-10 Amps Wall Hanging Time Delay-6 to minutes Inbuilt thermal overload protector.	
5	Submeter(Electric)		

Chief District Medical  
& Public Health Officer  
Joiner

*(Handwritten Signature)*